


## IMPROVEMENT PERMIT and CONSTRUCTION AUTHORIZATION ON-SITE WASTEWATER

Applicant/Owner Old Mud Creek, LLC, (new owner B.J. Fischer)			Log #	093621-S	PDWW#	Existing				
<b>Location</b> Lot 1, Mountain Breeze S/D	PID#	7408223603	ACREAGE	0.37						
Directions Right on Old Mud Creek Rd off Dillard Road to R on Mountain Breeze Rdg., to first lot on left.										
Design 240 Gallons Per Day	Facility	Two Bedroom	Permit	Type New Co	onstruction					
Foundation Crawlspace	<b>Water Source</b>	Existing Shared Well / Off Site	Expira	ation Valid fo	or 60 Months					

## Permit Conditions

This is a permit to install a two bedroom one structure only septic system. An RV may be used until a Tiny home is built. The area is maxed out due to the size of the lot. All setbacks must be maintained with the septic and repair areas. Divert all storm water away from the septic area.

Contact Health Department for final inspection one to two prior notice required.



TO BE INSTALLED	25% Reduction – Gravity;				REPAIR	T&J Panel Block (PPBPS) - Horizontal – Effluent Pump;			
Type IIa	Soil Depth: 48(in)	Slope: 13%	LTAR: 0.6	Saprolite: No	Type IIIb	Area:400(ft <sup>2</sup> )	LTAR: 0.6	Saprolite: No	
CONSTRUCTION	<b>TOTAL LENGTH</b>	# OF LINES	MIN SPACING	MAX DEPTH	WIDTH	DISTRIBUTION	SEPTIC TANK	<b>PUMP TANK</b>	
AUTHORIZATION	100 `	2	9 ' on center	18 " low side	36 inches	Serial - PVC	1000 gallon	Not Required	

The issuance of this permit by MCPH in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This permit is subject to revocation if the site plan, plat, site or intended use changes. This permit is subject to compliance with the provisions of the NC Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Construction and installation Rules NCAC .1950, .1952, .1954, .1955, .1956, .1957, .1958 and .1959 are incorporated by reference into this permit and shall be met. **Questions? (§28) 349-2490** 

Issue Date: 9/20/2022 Charles Womack, REHS 1300 Marker Joynan Authorized State Agent