



STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
ONSITE SEWAGE TREATMENT AND DISPOSAL SYSTEM

PERMIT NO. _____

SITE EVALUATION AND SYSTEM SPECIFICATIONS

APPLICANT: ACTIVE ACRES PROPERTIES LLC

AGENT: _____

LOT: 38 BLOCK: A SUBDIVISION: HOLIDAY HEIGHTS

PROPERTY ID #: L24C038 [Section/Township/Parcel No. or Tax ID Number]

TO BE COMPLETED BY ENGINEER, HEALTH DEPARTMENT EMPLOYEE, OR OTHER QUALIFIED PERSON. ENGINEERS
MUST PROVIDE REGISTRATION NUMBER AND SIGN AND SEAL EACH PAGE OF SUBMITTAL. COMPLETE ALL ITEMS.

PROPERTY SIZE CONFORMS TO SITE PLAN: YES NO NET USABLE AREA AVAILABLE: 1.21 ACRES

TOTAL ESTIMATED SEWAGE FLOW: _____ GALLONS PER DAY [TABLE I / OTHER]

AUTHORIZED SEWAGE FLOW: _____ GALLONS PER DAY [1500 GPD/ACRE OR 2500 GPD/ACRE]

UNOBSTRUCTED AREA AVAILABLE: _____ SQFT UNOBSTRUCTED AREA REQUIRED: _____ SQFT

BENCHMARK/REFERENCE POINT LOCATION: _____

ELEVATION OF PROPOSED SYSTEM SITE IS _____ [INCHES/FT] [ABOVE/Below] BENCHMARK/REFERENCE POINT

THE MINIMUM SETBACK WHICH CAN BE MAINTAINED FROM THE PROPOSED SYSTEM TO THE FOLLOWING FEATURES

SURFACE WATER: _____ FT DITCHES/SWALES: _____ FT NORMALLY WET? YES NO

WELLS: PUBLIC: _____ FT LIMITED USE: _____ FT PRIVATE: _____ FT NON-POTABLE: _____ FT

BUILDING FOUNDATIONS: _____ FT PROPERTY LINES: _____ FT POTABLE WATER LINES: _____ FT

SITE SUBJECT TO FREQUENT FLOODING: YES NO 10 YEAR FLOODING? YES NO

10 YEAR FLOOD ELEVATION FOR SITE: _____ FT MSL/NGVD SITE ELEVATION: _____ FT MSL/NGVD

SOIL PROFILE INFORMATION SITE 1

MUNSELL #/COLOR	TEXTURE	DEPTH
10 YR 4/2	FS	0 TO 9
10 YR 5/4	FS	9 TO 20
10 YR 6/4	FS	20 TO 39
10 YR 6/6	FS	39 TO 72
	TO	
USDA SOIL SERIES:	CANDLER LIKE	

SOIL PROFILE INFORMATION SITE 2

MUNSELL #/COLOR	TEXTURE	DEPTH
10 YR 4/2	FS	0 TO 12
10 YR 5/4	FS	12 TO 27
10 YR 6/4	FS	27 TO 40
10 YR 6/6	FS	40 TO 72
	TO	
USDA SOIL SERIES:	CANDLER LIKE	

OBSERVED WATER TABLE: +72 INCHES [ABOVE / BELOW] EXISTING GRADE. TYPE: [PERCHED / APPARENT]
ESTIMATED WET SEASON WATER TABLE ELEVATION: +72 INCHES [ABOVE / BELOW] EXISTING GRADE
HIGH WATER TABLE VEGETATION: YES NO WSWT INDICATOR: YES NO DEPTH: _____ INCHES

SOIL TEXTURE/LOADING RATE FOR SYSTEM SIZING: SCL.65 DEPTH OF EXCAVATION: _____ INCHES

DRAINFIELD CONFIGURATION: TRENCH BED OTHER (SPECIFY) _____

REMARKS/ADDITIONAL CRITERIA: _____

BORINGS WHERE DONE TOWARDS THE SOUTH SIDE OF THE SITE NEAR. EXACT LOCATION WILL NEED TO BE DONE ONCE SEPTIC AREA IS DETERMINED
SYSTEM SPECS WILL BE BASED ON CODE REQUIREMENTS AT THE TIME OF PERMITTING PER CODE.

SITE EVALUATED BY: *Elias Christ* ELIAS CHRIST CEHP 25-0900 DATE: 01/05/2026

DEP 4015, 06-21-2022 (Obsoletes previous editions which may not be used)

Incorporated: 62-6.004, FAC

Page 3 of 4