

[illegible]



ladner testing laboratories, inc

2832 Utica Avenue/Post Office Box 10778/Jackson, Mississippi 39289-0778 / (601) 362-5421
2123 Glendale Avenue/ Hattiesburg, Mississippi 39402/ (601) 544-5782
P.O. Box 2363/ Gulfport, Mississippi 39505/ (228) 604-2527

PROJECT: TISDALE ROAD MADISON, MS		CLIENT: JOHN LUTZ 429 WEST OAK CIRCLE MADISON, MS 39110		DATE: 2/10/2025 LAB NO: 0078-25-A BORE NO: B-2 TECHNICIAN: B.H. / M.S.					
SAMPLES:		AUGER(ASTM D-1452)		TUBE(ASTM D-1587)		X		PENETRATION TEST(ASTM D-1586)	
DEPTH	SAMPLE	VISUAL DESCRIPTION - REMARKS	CONSISTENCY	FIELD MOIST %	LL%	PI %	PASS #200 %	UNIFIED CLASS	STD. PEN
0		BROWN LEAN CLAY (0 - 1')		25.0	35.0	13.0	93.4	CL	
		TAN & GRAY LEAN CLAY (1' - 5')		16.5	36.0	13.0	96.1	CL	
5		TAN & GRAY LEAN CLAY W/TRACE CALCAREOUS (5' - 7')		15.1	43.0	23.0	97.1	CL	
		TAN & GRAY HEAVY CLAY (7' - 10')		18.3	50.0	31.0	95.8	CH	
10									
15									
20									
25									
30									

WATER DEPTH 0 FT.	AFTER 0 HRS.	BORING ELEVATION 0 FT.
WATER DEPTH 0 FT.	AFTER 0 HRS.	BORING TERMINATED AT 10 FT.

TISDALE ROAD

MADISON, MS

DATE: 2/10/2025

LAB NO.: 0078-25-A

Legend

B-2



B-1

Google Earth

Image © 2025 Airbus



200 ft