

NEW MEXICO OFFICE OF THE STATE ENGINEER
WELL RECORD

1. OWNER OF WELL

Name: Gerald W. Lathem Work Phone: 505-821-2585
Contact: 9504 Admiral Lowell NE Home Phone: 505-821-9005
Address: _____
City: Albuquerque, State: NM Zip: 87111

2. LOCATION OF WELL (A, B, C, or D required, E or F if known)

A. 1/4 1/4 1/4 Section: 27 Township: 02N Range: 1207E N.M.P.M. 27E
Socorro County.

B. X = 324590.0 feet, Y = 1227462.0 feet, N.M. Coordinate System 21-NAD 1927
SP 77 NM Central Zone in the Sevilleta Grant.
U.S.G.S. Quad Map _____

C. Latitude: _____ d _____ m _____ s Longitude: _____ d _____ m _____ s

D. East _____ (m), North _____ (m), UTM Zone 13, NAD _____ (27 or 83)

E. Tract No. 22, Map No. 139 of the MRGCD Hydrographic Survey

F. Lot No. _____, Block No. _____ of Unit/Tract _____ of the
Lands of Juan Jose Martinez Subdivision recorded in Socorro County.

G. Other: _____

H. Give State Engineer File Number if existing well: _____

I. On land owned by (required): Applicant

3. DRILLING CONTRACTOR

License Number: WD-1148
Name: Husky Drilling Co. Work Phone: 505-864-0779
Agent: _____ Home Phone: _____
Mailing Address: 707 E. River Road.
City: Belen, State: NM Zip: 87002

4. DRILLING RECORD

Drilling began: 09-07-06; Completed: 09-02-06; Type tools: Rotary
Size of hole: 7 7/8 in.; Total depth of well: 300 ft.;
Completed well is: shallow (shallow, artesian);
Depth to water upon completion of well: 25 ft.

STATE ENGINEER OFFICE
ALBUQUERQUE, NEW MEXICO

SEP 11 PM 4:34

**NEW MEXICO OFFICE OF THE STATE ENGINEER
WELL RECORD**

5. PRINCIPAL WATER-BEARING STRATA

Depth in Feet		Thickness in feet	Description of water-bearing formation	Estimated Yield (GPM)
From	To			
285	300	15	Medium Gravel	25

6. RECORD OF CASING

Diameter (inches)	Pounds per ft.	Threads per in.	Depth in Feet		Length (feet)	Type of Shoe	Perforations	
			Top	Bottom			From	To
4"	pvc	pvc	0	285	20	pvc screen	285	300

7. RECORD OF MUDDING AND CEMENTING

Depth in Feet		Hole Diameter	Sacks of mud	Cubic Feet of Cement	Method of Placement
From	To				

8. PLUGGING RECORD

Plugging Contractor: _____
 Address: _____
 Plugging Method: _____
 Date Well Plugged: _____

Plugging approved by: _____
 State Engineer Representative

No.	Depth in Feet		Cubic Feet of Cement
	Top	Bottom	
1			
2			
3			
4			
5			

