Send original copy by certified mail to: TNRCC, P.O. Box [illegible]7, Austin, TX 78711-3087

Please use black ink.

ATTENTION OWNER: Confidentiality Privilege Notice on Reverse Side

State of Texas WELL REPORT

Texas Water Well Drillers Advisory Council
P.O. Box 13087
Austin, TX 78711-3087
512-239-0530

1) OWNER Bill Pettit (Name) ADDRESS 2502 Pettit Ln. Schulenburg TX 78956 (Street or RFD) (City) (State) (Zip)

2) ADDRESS OF WELL: County Fayette 2502 Pettit Ln. Schulenburg TX 78956 (Street, RFD or other) (City) (State) (Zip) GRID # 66-17-2

3) TYPE OF WORK (Check): [X] New Well [ ] Deepening [ ] Reconditioning [ ] Plugging

4) PROPOSED USE (Check): [ ] Monitor [ ] Environmental Soil Boring [X] Domestic [ ] Industrial [ ] Irrigation [ ] Injection [ ] Public Supply [ ] De-watering [ ] Testwell
If Public Supply well, were plans submitted to the TNRCC? [ ] Yes [ ] No

5)

6) WELL LOG:
Date Drilling: Started 7-15 19 96 Completed 7-15 19 96

DIAMETER OF HOLE

Dia. (in.)	From (ft.)	To (ft.)
6½	Surface	165

7) DRILLING METHOD (Check): [ ] Driven [ ] Air Rotary [X] Mud Rotary [ ] Bored [ ] Air Hammer [ ] Cable Tool [ ] Jetted [ ] Other

N

From (ft.)	To (ft.)	Description and color of formation material
0	2	Top Soil
2	4	Brn, clay
4	10	White clay
10	15	Sand
15	40	White clay
40	50	Sand
50	60	Rock & Sand / Rivers
60	70	Blue & Brn Clay
70	90	Blue clay & Fine Sand
90	115	Blue Sand & Rock.
115	125	Blue & Brn Clay
125	145	Brn, clay,
145	165	Red, white, Brn clay

(Use reverse side if necessary)

8) Borehole Completion (Check): [X] Open Hole [ ] Straight Wall [ ] Underreamed [ ] Gravel Packed [ ] Other
If Gravel Packed give interval ... from ft. to ft.

CASING, BLANK PIPE, AND WELL SCREEN DATA:

Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft.) From	Setting (ft.) To	Gage Casting Screen
4	N	Sch 40 PVC	0	90	
4	N	Sch 40 Slotted	90	110	.025

RECEIVED
SEP 24 1996
TEXAS NATURAL RESOURCE CONSERVATION COMMISSION

9) CEMENTING DATA [Rule 338.44(1)]
Cemented from 0 ft. to 15 ft. No. of sacks used 12
ft. to ft. No. of sacks used
Cemented by Allan Roeder
Distance to septic system field lines or other concentrated contamination 200 ft.
Method of verification of above distance Owner Diagram

10) SURFACE COMPLETION
[X] Specified Surface Slab Installed [Rule 338.44(2)(A)]
[ ] Specified Steel Sleeve Installed [Rule 338.44(3)(A)]
[ ] Pitless Adapter Used [Rule 338.44(3)(b)]
[ ] Approved Alternative Procedure Used [Rule 338.71]

11) WATER LEVEL:
Static level 49 ft. below land surface Date 7-16-96
~~Artesian~~ 53 gpm. Date 4-14-26

12) PACKERS: Type Depth
Rubber - 15' & 90'

13) TYPE PUMP:
[ ] Turbine [ ] Jet [ ] Submersible [ ] Cylinder
[ ] Other
Depth to pump bowls, cylinder, jet, etc., ft.

14) WELL TESTS: Pumps 15 gpm at 86' 4-14-26
Type test: [ ] Pump [ ] Bailer [X] Jetted [ ] Estimated
Yield: 15 gpm with 5 ft. drawdown after 4 hrs.

15) WATER QUALITY:
Did you knowingly penetrate any strata which contained undesirable constituents?
[ ] Yes [X] No If yes, submit "REPORT OF UNDESIRABLE WATER"
Type of water? Good Depth of strata
Was a chemical analysis made? [ ] Yes [X] No

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. I understand that failure to complete items 1 thru 15 will result in the log(s) being returned for completion and resubmittal.

COMPANY NAME Allan's (Type or print) WELL DRILLER'S LICENSE NO. 2117 WPL

ADDRESS 4449 FM 957 (Street or RFD) Schulenburg (City) TX (State) 78956 (Zip)

(Signed) Allan Roeder (Licensed Well Driller) (Signed) (Registered Driller Trainee)

Please attach electric log, chemical analysis, and other pertinent information, if available.

TNRCC-0199 (Rev. 11-01-94) TNRCC COPY