

Health Department Use Only – Do Not Write in This Section

APPROVED SYSTEMS

Gravity Feed _____ Flood Dosed ☒ Elevated Sand Lined System* _____ (Mound/ATL/Presby)

*Elevated Sand Lined System specs can be provided upon request once the owner/agent determines which system they intend to use.

Minimum System Requirements

Absorption Field 1500 Sq Ft Absorption Field If Using Chambers 1125 Sq Ft Tank Size 1000 Gallons

Dosing Tank Size 750+ Gallons Dosing Pump Volume 450 GPD 30-45 GPM

Trench Depth (Gravity Fed) Min _____ Max _____ Trench Depth (Flood Dosed) Min 10" Max 15"

Drainage

Drainage Required: Yes _____ No ☒ Around Entire System _____ Upslope Only _____ Site Slope 0-6%

Drain Depth _____

If the perimeter drain outlet is being connected to a county regulated drain, permission must be obtained in writing, from the Madison County Surveyors Office and provided to this office. All parts of the sewage disposal system must be at least 50 feet from any water well.

Notes

- Please show soil borings on plans
- Please show well w/ 50 ft radius drawn on plans
- Please show all system elevations on plans. (inlets, outlets, laterals, etc.)
- System is Flood dosed due to poor filter at 39".

System type is based upon an onsite evaluation conducted by this office, a written soil report from a qualified soil scientist and ISDH Rule 410 IAC 6-8.3. Some sites may require a more extensive system depending on location and layout of the property.

This application will be considered pending until all information deemed necessary by the Health Officer or his/her designee, has been provided to the Madison County Health Department by the owner/agent. No permit will be issued until all information is provided by the owner/agent and approved by the Health Officer or his/her designee.

Phillip Goshert, M.D.
Health Officer

Stephenie R. Mellinger
Administrator



July 24, 2025

Allan Harpe
516 Green St.
Tipton, In 46072

Dear Applicant,

Enclosed please find a copy of your application for a sewage disposal permit. Written installation plans must be submitted to this office for review and approved by an Environmental Sanitarian prior to a sewage disposal system permit being issued.

Upon installation plan approval for new home construction, applicant must obtain property address from Madison County Planning Commission. Following plan approval and the office receiving a property address, applicant may purchase a sewage disposal permit.

When this process is complete, you may purchase your permit for \$150.00 (\$100.00 permit fee and \$50.00 inspection fee – correct change, check or money order) from our office. No work shall be started on the sewage disposal system until a sewage disposal permit is purchased. Upon completion, a representative of our office will conduct a final inspection of the system before the system is covered. No system shall be installed during adverse weather and/or soil conditions.

If you have any questions, please contact Joe Davis at 765-641-9537.

Respectfully,

Joe Davis

Joe Davis
Environmental Supervisor

Enclosure: copy of sewage disposal permit application
JD/js