

CERTIFICATE NO: 11546

TOWNSHIP: HARRISON

SECTION: 19

BARTHOLOMEW COUNTY HEALTH DEPARTMENT
440 THIRD STREET - SUITE 303
COLUMBUS, IN 47201-6798
PHONE: (812) 379-1550 FAX: (812) 379-1040

PRELIMINARY SEWAGE CERTIFICATE
(NOT A CONSTRUCTION PERMIT)

FRONTING ON: NORTH SIDE OF COUNTY ROAD: OLD NASHVILLE ROAD APPROXIMATELY: 0'

FEET/MILES: WEST OF COUNTY ROAD: 580 NORTH (NEAREST CROSS ROADS)

ACRES: 26.5 DIMENSIONS: _____

SUBDIVISION: SITE 1 LOT NO: 187A

OWNER'S NAME: BRS 9170 LLC

MAILING ADDRESS: 9170 WEST OLD NASHVILLE ROAD COLUMBUS, IN 47201

SURVEYOR: _____

SOIL SCIENTIST: MIKE SALEM SOIL ANALYSIS DATE: 3/5/2025

REQUIREMENTS

1. Install a septic tank sized according to the number of bedrooms in the home, equipped with an outlet filter and a gas tight riser.
2. Install 500 square feet of subsurface absorption field per bedroom in trenches not to exceed 11 inches in depth. Apply a minimum of 12 inches of soil cover, graded to promote surface water runoff.
3. Install an interceptor drain along the upslope and side slopes of the system area at 43 inches in depth, located no closer than 10 feet to any part of the system area.
4. The system area must be located no closer than 50 feet to all private water supplies.
5. The system must be laid out and approved prior to the issuance of a construction permit.
6. The system area must be located approximately 100 feet Southeast of pond, 98 feet West of soil site #2, and nearly directly behind 9170 W Old Nashville Road.
7. The system area must be protected from all construction related activities including grading, filling, and compaction.
8. If the home has three or more bedrooms, it must be flood-dosed.

OWNER/AGENT SIGNATURE: Samuel Goin

DATE: 4/4/25

COMPLETED BY: TRAVIS ANDERSON

DATE: 4/4/25

CERTIFICATE NO: 11547

TOWNSHIP: HARRISON

SECTION: 19

BARTHOLOMEW COUNTY HEALTH DEPARTMENT
440 THIRD STREET - SUITE 303
COLUMBUS, IN 47201-6798
PHONE: (812) 379-1550 FAX: (812) 379-1040

PRELIMINARY SEWAGE CERTIFICATE

(NOT A CONSTRUCTION PERMIT)

FRONTING ON: NORTH SIDE OF COUNTY ROAD: OLD NASHVILLE ROAD APPROXIMATELY: 0'

FEET/MILES: WEST OF COUNTY ROAD: 580 NORTH (NEAREST CROSS ROADS)

ACRES: 26.5 DIMENSIONS: _____

SUBDIVISION: SITE 2 LOT NO: 4 18 1A

OWNER'S NAME: BRS 9170 LLC

MAILING ADDRESS: 9170 WEST OLD NASHVILLE ROAD COLUMBUS, IN 47201

SURVEYOR: _____

SOIL SCIENTIST: MIKE SALEM SOIL ANALYSIS DATE: 3/5/2025

REQUIREMENTS

1. Install a septic tank sized according to the number of bedrooms in the home, equipped with an outlet filter and a gas tight riser.
2. Install 500 square feet of subsurface absorption field per bedroom in trenches not to exceed 13 inches in depth. Apply a minimum of 12 inches of soil cover, graded to promote surface water runoff.
3. Install an interceptor drain along the upslope and side slopes of the system area at 39 inches in depth, located no closer than 10 feet to any part of the system area.
4. The system area must be located no closer than 50 feet to all private water supplies.
5. The system must be laid out and approved prior to the issuance of a construction permit.
6. The system area must be located approximately approximately 101 feet Southeast of pond and 98 feet East of soil site # 1.
7. The system area must be protected from all construction related activities including grading, filling, and compaction.
8. If the home has three or more bedrooms, then the system must be flood-dosed.

OWNER/AGENT SIGNATURE: *Samuel G. [Signature]*

DATE: 4/4/25

COMPLETED BY: *Travis Anderson*

DATE: 4/4/25