Permit No. 9641

COMPLETION REPORT

APPROVED

Private Sewage Disposal System

Owner [redacted]

Mailing Address [redacted]

Site Address 4299 Lewis Access Road Center Point, IA 52213

Family Units 1 Bedrooms 3 Contractor Kenny Griener

Legal Description of Installation Site

Township # 85N Range # 8W Section # 16 Lot # —

Addition — Township Name Washington

Water Supply

Municipal _____ Community Well (public) _____ Shared Well _____ Private Well ✓

Method of Effluent Disposal

Subsurface Absorption ✓ Surface Discharge (type) _____

Septic Tank

Distance From Well not yet drilled No. Compartments 2 Material Concrete

Liquid Capacity Below Outlet 2/3 Capacity Inlet Compartment 1500 gals

Absorption Field

Type: Gravel Trench ✓ 10" Gravelless _____ Other _____

Distance from well not yet drilled Distance from foundation > 25'

Total length of laterals 270' No. of lines 3 Trench Width 18"

Total area of trench bottom 405 ft.² Type filter material gravel

Depth of tile below finish grade 8" - 12" Depth gravel below tile 12"

System installed in accordance with plans submitted on application for permit?

☒ YES

☐ NO (Give details on changes) In addition to a 3 bedroom home system serves an office. Home building sewer line not installed.

01-05-96
Date of Inspection

Timothy D. Clay
Inspector

Linn County Board of Health

This APPROVAL in no way makes the County responsible for the continued operation of the installation system

ENV-S-4-89

✓

A to tank lid = 48'
B to tank lid = 90'

A to 1st drop box = 50'
B to 1st drop box = 100'

C to. septic tank lid = 32'
C to A = 61'.

