

UGL 12 1977

State of Wisconsin
Department of Natural Resources
Box 450
Madison, Wisconsin 53701

NOTE:
White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT
Form 3300-15
Rev. 10-75

JU-149-6

1. COUNTY JUNEAU CHECK (✓) ONE: Town Village City Name FOUNTAIN

2. LOCATION NE, SE 1/4 Section NE 1/4 Section 16 Township 16-N Range 2-E 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE NORMAN O. OLSON WELL # 1

OR - Grid or Street No. Street Name ADDRESS RT 2 PERM. WELL # 12928

AND - If available subdivision name, lot & block No. POST OFFICE CAMP DOUGLAS, WIS.

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer: San. Storm Other Sewers: C.I. Other Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump C.I. Other Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit: Seepage Pit Seepage Bed Seepage Trench

Privy: Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description) JUNEAU CO. IRRIG. # 24

5. Well is intended to supply water for: IRRIGATION WELL

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
15"	Surface	65 1/2'				SAND	Surface	52'
12"	65 1/2'	305'				SANDSTONE	52'	305'

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
12"	NEW STEEL .375 WALL 49.56 LBS PER FT. WELDED	Surface +15"	65 1/2'

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
NEAT CEMENT	Surface	65 1/2'

9. FORMATIONS

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on 6-10- 1977

Well is terminated 15 inches above final grade below

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

11. MISCELLANEOUS DATA

Yield Test: 4 Hrs. at 600 GPM

Depth from surface to normal water level 16 Ft.

Depth of water level when pumping 67 Ft. Stabilized Yes No

Water sample sent to _____ laboratory on _____ 19__

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature D.L. Kaula Registered Well Driller Complete Mail Address 578 WATER AVE. HILLSBORO, WIS. 54634

867

WGNHS ORIGINAL

p. 6 t