dhec

PERMIT TO CONSTRUCT
Onsite Wastewater System

File No.: 2023 01 0002
County: 23

Name: ALEX KIRIAKIDES
Type Facility: HOUSE
Subdivision: DAKOTA HILLS
Block: 3 Bdr. Lot: 26+27

Address: 1061 ALEXANDER RD
GUL, SC 29609
Site: 130 BISMARK DR.
PELZER SC

Program Code: 360
System Code: 818
TM No.: 0603010103300
Water Supply: PUBLIC

PERMIT TO CONSTRUCT SYSTEM SPECIFICATIONS

Daily Flow (gpd): 360 **Tank Sizes (gal):** Septic Tank: 1000 Pump Chamber: — Grease Trap: —

LTAR: .3 **Trenches:** Length (ft): 300' Width (in): 36" Max. Depth (in): 34" Agg. Depth (in): 12"

Min. Pump Capacity: — gpm at — ft. of Head Alternative Product: ARC36

SPECIAL INSTRUCTIONS/CONDITIONS

THIS PERMIT IS SITE SPECIFIC. ANY CHANGES TO THE SYSTEM MUST BE APPROVED BY DHEC. ALTERNATIVE TRENCH PRODUCTS APPROVED UNDER STATE RULES AND REGULATIONS MAY BE SUBSTITUTED. ANY UNAPPROVED CHANGES WILL VOID THIS PERMIT.

Installers must contact the local Environmental Affairs office by 10:00 AM the day prior to installation in order to schedule a time for the final inspection. If a Department representative does not arrive within 30 minutes of the scheduled time, the installer may conduct the final inspection. When a contractor self-inspection occurs, the installer must complete the DHEC form 3978, Approval to Operate Contractor Self-Inspection. The installer must submit the DHEC form 3978 within 2 business days of the completion of the installation.

PERMIT TO Construct


Designed using alternative products. No further reduction

Maintain 75' offset to creek.

25' offset to any basement walls.

Any changes to house site may cause additional soil work and may void this permit.

DO NOT Remove any soils from site.



(NTS)

Issued/Revised By: Alex Hawkins Date: 5/25/2023

DHEC 1781 (07/2020)

This Permit is appealable under the Administrative Procedures Act. This Permit will expire and become null and void five (5) years from the issuance date. There may be an additional fee for changes in this Permit that require a site reevaluation.

Personal information provided on this form is subject to public scrutiny or release.