



The Jackson County Department of Public Health
538 Scotts Creek Rd. Suite 100 * Sylva, NC 28779
Tel: 828-586-8994 * FAX: 828-586-3493
Shelley Carraway
DIRECTOR
Shelley Carraway

Improvement Permit

Reference Number:

PIN: 7641-31-9164
Owner: HOOK, JAMES S
Address: 117 BROOKHAVEN DR
Lot Number: LT 4 REV HOLLYWALK
Service Type: IP
Directions To Site: Holley Walk Lot #4

Permit Number: 2023-24984-9-12932
Application Date: 5/8/2023
City: BLACK MOUNTAIN NC
Zip Code: 28711
Bedrooms: 3

Initial System Type: IIIG - 25% REDUCTION
LTAR: .45

Repair System Type: DRIP IRRIGATION
Water Source: COMMUNITY WELL

Remarks: AREA FOUND FOR A SYSTEM ADEQUATE FOR 3 BEDROOMS 360 GPD MAXIMUM OCCUPANCY 6 PEOPLE UTILIZING A IIIg 25% REDUCTION TYPE SYSTEM FOR THE INITIAL SEPTIC AREA. FOR THE REPAIR A DRIP IRRIGATION TYPE SYSTEM WILL BE USED.

A pump may be required depending on finished floor elevation. Do not excavate, fill or stump over proposed septic areas. Exact house and driveway shall be marked on the ground to scale prior to the issuance of a construction authorization. Maintain repair areas.

THIS PERMIT EXPIRES ON: 5/9/2028

Fee: \$360.00

EHS:

[Handwritten Signature] #2994

Signature: _____

Receipt: _____

Date: 5/9/2023


Date: _____



Jackson County Department of Public Health
538 Scotts Creek Road, Suite 100
Sylva, NC 28779
Phone: (828) 587-8250 FAX: (828) 586-1207

Improvement Permit

Reference Number:		Permit Number:	2023-24984-9-12932
PIN:	7641-31-9164	Application Date:	5/8/2023
Owner:	HOOK, JAMES S	City:	BLACK MOUNTAIN NC
Address:	117 BROOKHAVEN DR	Zip Code:	28711
Lot Number:	LT 4 REV HOLLYWALK	Bedrooms:	3
Service Type:	IP		
Directions To Site:	Holley Walk Lot #4		



Fee: \$360.00

EHS: *[Signature]* #2994

Signature: _____

Receipt: _____

Date: 5/9/2023

Date: _____