



The Jackson County Department of Public Health
538 Scotts Creek Rd. Suite 100 * Sylva, NC 28779
Tel: 828-586-8994 * FAX: 828-586-3493

Shelley Carraway
DIRECTOR
Shelley Carraway

Authorization to Construct

Reference Number:

PIN: 7539-08-8196
Owner: JORDAN, DARRIN D
Address: 1116 S WINDSOR DR
Lot Number: LT 9 COLE MTN
Service Type: CA / OP
Directions To Site: 288 Blue Cedar RD

Permit Number: 2023-26101-9-13996

Application Date: 8/19/2024

City: KANNAPOLIS NC

Zip Code: 28081

Bedrooms: 3

Initial System Type: IIB-25% REDUCTION

Distribution: D-BOX OR STEP-DOWNS

Minimum Grade level: II

Nitrification: 720 SQ FT

Pump Tank Size: N/A

Repair System Type: IIIe SHALLOW PLACED PPBPS

Septic Tank Size: 1000 GALLON

Water Supply: COMMUNITY WATER

SYSTEM ADEQUATE FOR 3 BEDROOM 360 GPD MAXIMUM OCCUPANCY 6 PEOPLE

->INSTALL A 1000 GALLON SEPTIC TANK.

->INSTALL / FEED TO 180 LINEAR FEET OF A IIB 25% REDUCTION TYPE DRAINLINES (see drawing).

->TRENCH WIDTH 36", TRENCH DEPTH WILL BE 18" ON THE LOWSIDE OF THE TRENCH.

->TRENCHES SHALL BE DUG LEVEL AND ON CONTOUR, STAYING 9' CENTERS MINIMUM.

Remarks:

20' shall be maintained between systems. A Pre-Construction meeting is required prior to installation. Attached drawing not to scale. Check for any and all underground utilities prior to construction. Do not fill over proposed septic area. Stay 10' from any property line. Stay 10' from any water line. Stay 100' from any Well. Stay 15' from any cut bank 2' or greater. Stay 15' from retaining walls. Stay 5' from any foundation, including decks. Supply line shall be buried a minimum of 30" deep when crossing a driveway, or it shall be encased in ductile iron.

THIS PERMIT EXPIRES ON: 8/23/2029

Fee: \$120.00

EHS:

Signature:

Receipt:

Date:

Date:

8/23/24

#2894



Jackson County Department of Public Health
538 Scotts Creek Road, Suite 100
Sylva, NC 28779
Phone: (828) 587-8250 FAX: (828) 586-1207

Authorization to Construct

Reference Number:

Permit Number: 2023-26101-9-13996

PIN: 7539-08-8196

Application Date: 8/19/2024

Owner: JORDAN, DARRIN D

City: KANNAPOLIS NC

Address: 1116 S WINDSOR DR


Zip Code: 28081

Lot Number: LT 9 COLE MTN

Bedrooms: 3

Service Type: CA / OP

Directions To Site: 288 Blue Cedar RD



*Drawing not to scale
N *H₂O from Community well

Fee: \$120.00

EHS:

Signature:

Receipt:

Date:

Date:

8/23/24