

CDP# 24630


SWAIN COUNTY HEALTH DEPARTMENT
OPERATIONS PERMIT#
AC# 003496

Owner Javier Chacon Date 06/05/09
 Location 28 South to Sawmill, on the left to #425
on the left uphill to lot on the right.
 Subd. _____ Lot# _____ Water Sup. Spring
 House Yurt Mobile Home _____ # Bedrooms 3BR
 Other _____ # Emp _____ Daily flow 360 GPD.

Tank size 1000 Gallon
 Manufacturer SCM-1000
 Stone depth _____
 Type System Easylog - 25% Reduction
 New Const. 220 sq. ft.
 Repair 220 sq. ft.
 Review Insp. freq. _____

(Not to Scale)
 Do not disturb Initial or Repair Areas.
 Place marker over ST.
 Maintain the following setbacks!

100' H₂O Source, 15' Surface H₂O drains,
 10' Prop & H₂O Lines, 5' foundation.



Shannon Taylor

Installed by

Lic# 2331

EHS

J. B. J. R. S.

Notice: This approval is issued subject to all the provisions of Article 11, G.S. 130A 333-339 of the General Statutes of North Carolina and Laws and Rules for Sanitary Sewage Collection, Treatment, and Disposal, Section 1900 of the North Carolina Administrative Code. No person is permitted to make alterations in the design or use of this system other than its use without approval of an authorized Environmental Health Specialist. This approval indicates that this system has been installed in compliance with the standards as set forth in the above regulation, but shall in no way be taken as a guarantee that the system will function properly.